

ADDENDUM NO. 4

This Addendum shall become and form a part of the drawings and specifications for the project:

INTERIOR RENOVATION OF
RIVERSIDE DEVELOPMENTAL DISABILITIES
at
Miami County Board of Developmental Disabilities
1625 Troy Sidney Road
Troy, Ohio
45373

Prepared for
Miami County Board of Developmental Disabilities
1625 Troy Sidney Road
Troy, Ohio
45373

January 4, 2017

Prepared by

Ruetschle Architects
222 Linwood Street
Dayton, Ohio 45405
(513) 461-5390

TO ALL BIDDERS:

This Addendum, including all corrections listed hereinafter, shall become a part of the original contract drawings and specifications and shall be taken into account in preparing the "Proposal" and shall become a part of the Contract.

TO ALL BIDDERS:

The Architect requests that the Bidder bid the project in strict accordance with the drawings and specifications. Products which are not listed in the Specifications or in this Addendum as approved equals will not be accepted by the Architect. Products and manufacturers not listed in the Specifications or in this Addendum may be bid as Substitutions. The bidder is cautioned that Substitutions may be rejected, if upon later review, said Substitutions are found to be less than standard. Please review Section 01600 Products and Substitutions, especially paragraphs #2 and #4, in the Specifications.

CHANGES TO THE DRAWINGS

ITEM 1

Sheet A4.1 Partial Elevation 2. Reference is made to the new steel beam in Training Rooms 114 & 116. Neatly remove enough cmu at each existing masonry bearing wall as needed to allow for the installation of the new W 24 x 68 steel beam. Reinstall with new cmu around the steel beam after the beam is in place.

ITEM 2

Sheet A 6.1 Room Finish Schedule: replace base type RB2 with RB1.

END OF ADDENDUM NO.4

STATEMENT BY CONTRACTOR:

Each bidder shall sign the following acknowledgment and include it as an attachment to the proposal for: Interior Renovation of Riverside.

We acknowledge receipt of Addendum No.4, comprising reference to the following:

Addendum No. 4	ITEM 1	Clarification of sheet A4.1
	ITEM 2	Revision to sheet A6.1

Signed _____
(Contractor)

Date: _____